

# Mitech MDW-TLS Digital Manual Series Spring Tension /Compression

# **Testing Machine**

## Overview

Mitech MDW-TLS digital manual series Spring Tension /Compression Testing Machine, through manually loading the test force, for a variety of coil springs for tensile and compression test. It's adopts manually loading, computer control, digital intelligent display to achieve powerful function with stable performance, strong structure, high efficiency, simple operation. It's widely used in spring manufacturing, low-voltage electrical appliances, power machinery, institutions of higher learning and scientific research institutes and other fields and it is a necessary professional precision testing equipment to improve production efficiency and save production costs.

#### **Technical Parameters**

| Technical parameters                     | MDW-TLS10-200                  | MDW-TLS500-2000 |  |  |  |
|--|--------------------------------|-----------------|--|--|--|
| Maximum testing force                    | 10-200N                        | 500-2000N       |  |  |  |
| Indication error                         | ±1%                            |                 |  |  |  |
| Testing machine grade                    | Lev                            | vel 1           |  |  |  |
| Resolution on the testing force          | 0.001N                         | 0.01N           |  |  |  |
| Deformation<br>measurement<br>resolution | 0.01mm                         |                 |  |  |  |
| Effective range of test force            | 10%-100% of maximum test force |                 |  |  |  |
| Stretch effective space                  | 240mm                          | 270mm           |  |  |  |
| Compression effective space              | 220mm                          | 250mm           |  |  |  |
| Power supply                             | 220V                           |                 |  |  |  |
| Dimension                                | 600*430*900mm                  |                 |  |  |  |
| Total Weight                             | Approximately 70kg             |                 |  |  |  |
| Working Principle                        |                                |                 |  |  |  |

## Working Principle

Spring tension/compression testing machine measured by the force generated by the sensor signal amplified by the A / D converter into the digital signal is accepted by the computer system, the digital processing, the computer system to deal with the operation of A / D conversion Signal to the LCD display data.

## Features

MITECH CO., LTD



## MITECH CO.,LTD

Smvip@mitech-ndt.com

- Widely used in spring manufacturing, low-voltage electrical appliances, power machinery, institutions of higher learning and scientific research institutes and other fields;
- Modeling novel, strong structure, high reliability, simple operation, high precision measurement.
- Digital display, intuitive readings, high test efficiency;
- Circuit height integration, displacement, test force electronic detection, reduce the error caused by human factors;
- Equipped with a panel printer, real-time print test data;
- Consistent with GB, ISO, ASTM and other relevant domestic and foreign standards

## Scope of application

Widely used in spring mechanical performance test.

## Applications

- Spring manufacturing industry
- Power machinery enterprises
- Experimental teaching experiment in colleges and universities
- Scientific research institutions of material analysis test
- Quality inspection departments quality testing links

## Working Conditions

- Operation Temperature: room temperature ~ 45 °C;
- Humid Relativity: 20%~80%;
- In an environment free from vibration, no corrosive medium.
- Installed on a flat basis.

## Configurations

| Standard<br>Configuration | No. | Item                       | Quantity | Note |
|---------------------------|-----|----------------------------|----------|------|
|                           | 1   | Testing machine host       | 1        |      |
|                           | 2   | Electrical control cabinet | 1        |      |
|                           | 3   | Attached files             | 1        |      |

## Maintenance and care

- Before using this instrument, please read the instruction manual carefully, understand the operation steps and precautions, avoid the damage caused by improper operation or personal safety accident;
- Test machine is a large precision instruments, should pay attention to water, moisture. Exposed workstations, upper and lower beam parts and attached parts should be coated with anti-rust oil to prevent rust;
- If idle for a long time, at least once a week and move the upper and lower beams, so that beam position, silk mother often activities to prevent rust;
- The instrument should be test at least once a year to ensure the accuracy of the test machine;
- Electrical connection cable and equipment should be careful when connected, moderate efforts, remember not to swipe, hard pull.
- Don't disassemble the instrument without authorization, maintenance related matter, please contact MITECH after-sale service department with 4000600280